


INSTALLATION INSTRUCTIONS

1. ENSURE THE APERTURE IS CLEAN AND FREE OF DEBRIS.
2. CUT THE RYANBATT 802 TO FIT TIGHTLY BETWEEN THE TIMBER FRAMING AND THE COPPER PIPE, JOINS IN THE 802 SHOULD UTILISE A 40MM X 40MM SHIPLAP JOINT.
3. COAT ALL INTERNAL FRAMING WITH RYANFIRE MASTIC BRUSH GRADE.
4. COAT ALL RYANBATT 802 CUT EDGES AND JOINTS WITH RYANFIRE BRUSH GRADE MASTIC OR RYANFIRE MASTIC.
5. FIT THE RYANBATT 802 INTO THE VOID.
6. APPLY RYANFIRE MASTIC AROUND THE JUNCTION BETWEEN THE RYANBATT AND THE COPPER PIPE.
7. APPLY RYANFIRE MASTIC TO ALL OTHER JUNCTIONS.

OPTIONS TO INSTALL FROM ONE SIDE OF THE WALL ARE AVAILABLE. PLEASE CONTACT RYANFIRE FOR FURTHER DETAILS.



40MM X 40MM SHIPLAP JOINT

Products:	RYANBATT 802 RYANFIRE BRUSH GRADE MASTIC RYANFIRE MASTIC
Approval:	AS 1530.4/AS 4072.1
BK:	78
REF:	PF 20007
ID:	A
Scenario:	Copper pipe through Ryanfire Naked Wall System
Services:	Up to Ø80mm copper pipe
Construction:	90mm x 45mm timber framed wall
Fire Integrity:	60 minutes
Fire Insulation:	0 minutes

Web based drawings are for example only. Fire performance of any system is dependant on, but not limited to size of opening, substrate, if penetrations are passing through, type, size and number. Please refer to Ryanfire technical department for detailed and specific fire performance information.



Client
Job Title

Drawing Title
**Ryanfire 90mm Naked Wall System
 Copper Pipe**

<p>Please note: Ryanfire Products owns and has copyright in these drawings. They are to be used only for the purpose for which they were intended and supplied and are not to be sold, transferred or made available for use by a third party.</p> <p>Any misuse of these drawings will result in legal proceedings.</p>	<p>All errors and omissions excepted - the information contained within this drawing is believed to be correct on the date of publication, and is based upon tested and certified solutions. The policy of RyanFire Products is one of constant improvement. Installers must therefore ensure that they are following the latest published drawings, test evidence and instructions. Whilst RyanFire Products will endeavour to keep its publications up to date, the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of the manufactured products. Terms and conditions of sale apply.</p>
	<p>RYANFIRE Technical Support: info@ryanfire.co.nz - Tel 09 443 0362</p>

Scale	NTS	Date	August 2024
Sheet Size	A3	Drawn By	
Drawing Number	V5.2	Rev	6.0