


INSTALLATION INSTRUCTIONS

1. ENSURE THE APERTURE IS CLEAN AND FREE OF DUST AND DEBRIS.
2. OPTIONAL : MASK UP THE AREA AROUND THE GAP TO ENSURE A NEAT FINISH.
3. INSERT THE PEF BACKING ROD INTO THE GAP RECESSED TO THE APPROPRIATE DEPTH.
4. FILL THE RECESS WITH RYANFIRE MASTIC UNTIL FLUSH WITH THE SURFACE OF THE WALL.
5. REMOVE EXCESS MASTIC USING A DAMP CLOTH.
6. REPEAT THIS PROCESS ON THE OTHER SIDE OF THE WALL.



Products:	RYANSIL
Approvals:	AS 1530.4:2014/AS 4072.1:2005
BK:	342
Ref:	25SFR00039
ID:	B, C
Scenario:	Horizontal linear gap seal
Construction:	150mm Concrete / Masonry wall
Gap width:	Up to 35mm wide
Fill Ratio:	2:1 width to depth
Fire Integrity:	120 minutes
Fire Insulation:	120 minutes

Web based drawings are for example only. Fire performance of any system is dependant on, but not limited to size of opening, substrate, if penetrations are passing through, type, size and number. Please refer to Ryanfire technical department for detailed and specific fire performance information.



RYANFIRE Technical Support:
info@ryanfire.co.nz - Tel 09 443 0362

Drawing Title
**Ryansil horizontal linear seal
150mm concrete wall**

Scale	NTS	Date	June 2026
Drawing Number	V46.7	Rev	1.0

All errors and omissions excepted. The information contained within this drawing is believed to be correct on the date of publication, and is based upon tested and certified solutions. The policy of Ryanfire Products is one of constant improvement. Installers must ensure that they are following the latest published drawings, test evidence and instructions. Whilst Ryanfire Products will endeavour to keep its publications up to date, the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of the manufactured products. Terms and conditions of sale apply.

Ryanfire Products owns and has copyright to these drawings. They are to be used only for the purpose for which they were intended and supplied and are not to be sold, transferred or made available for use by a third party. Any misuse of these drawings will result in legal proceedings.